


The DESIR facility @ SPIRAL2


Some technical aspects

**DESIR: Désintégration, excitation et stockage d'ions radioactifs
(Decay, excitation and storage of radioactive ions)**

- **The DESIR hall and the RFQ-HRS ensemble**
- **Technical issues**
- **Safety issues**

SPIRAL 2 LAYOUT





DESIR building

Ground-floor: ~ 1500 m²


- * **experimental area: 1500 m²**
- * **laser room: 30 m²**
- * **stable ion source + RFQ cooler/buncher: 15 m²**
-
- * **Control room: 20 m²**
- * **Acquisition room: 30 m²**
- * **Meeting room: 25 m²**
- * **Kitchen: 12 m²**

DESIR building

Underground (?): ~ 750 m²

- * **technical workshop: 40 m²**
- * **grey room: 15 m²**
- * **grey room: 25 m²**
- * **assembling area: 25 m²**
- * **assembling area: 30 m²**
- * **assembling area: 40 m²**
- * **storage area: 4*10 m²**
- * **racks for operation: 30 m²**
- * **HV supplies (beam lines): 30 m²**
- * **HV supplies (equipments): 30 m²**
- * **power supplies (c/c racks): 10 m²**
- * **electricity room: 15 m²**
-
- * **liquid nitrogen tank (outside)**
- * **gas storage (baloon?)**

RFQ-HRS ensemble



F. Varenne, GANIL

42 m

Technical issues

DESCRIPTION	
Res pons able	Gilles BAN
Activité	RFQ cooleur
Description de l'activité	mise en paquets et refroidissement des fais ceaux
N° Téléphone	02 31 45 24 21
courriel	ban@lpccaen.in2p3.fr
Implantation	à décider, probablement bâtiment production, côte DES IR
Remarques	
Taille :	16 m2
servitudes :	air comprime + He, Ne, Ar réseau informatique électricité 220V électricité de puissance système de récupération de gaz eau de refroidissement eau de ville climatisation azote liquide

>> Next step (early 2008): precise description of the different elements
+ supply requirements + accesses + safety

Technical issues

Gas handling: storage, filtration, release

* preparation:

- 5 RFQ * 1 m³ * 5 interventions/an = **25 m³/an**

- beam lines : ($\Phi_{16\text{cm}} * 300 \text{ m} = 6 \text{ m}^3$) * 5 interventions/an
= **30 m³/an**


* permanent: ($5_{\text{RFQ}} * 5 \text{ m}^3/\text{an}$) = **25 m³/an**

>> global: **25 m³/an (permanent) + 55 m³/an (preparation)**

Safety issues

Readily accessible experimental areas >> Green zone

- $D_{ed} < 25 \mu\text{Sv/h}$
- $LDCA < 1$



Safety issues

Nuclide	Yield (10 ¹⁴ f/s)	Cumulative Yield	Induce d LDCA	Intensity reductio n	RFQ rejection factor	HRS masse resolution					
						$\Delta M(A;N,N-1)$	$\Delta M(A;N,N-2)$	$\Delta M(A;N,N-3)$	$\Delta M(A;N,N-4)$	$\Delta M(A;N,N-5)$	$\Delta M(A;N,N-6)$
⁷⁸ Ni	4,E+05	4,E+05	<1			1,E-04	3,E-04	4,E-04	5,E-04	5,E-04	6,E-04
⁷⁸ Cu	2,E+08	2,E+08	<1			2,E-04	3,E-04	4,E-04	4,E-04	4,E-04	
⁷⁸ Zn	8,E+09	8,E+09	2	2		9,E-05	2,E-04	2,E-04	3,E-04		
⁷⁸ Ga	3,E+10	4,E+10	8	8		1,E-04	1,E-04	2,E-04			
⁷⁸ Ge	1,E+10	5,E+10	11	11		1,E-05	7,E-05				
⁷⁸ As	5,E+08	5,E+10	5	5		6,E-05					
⁷⁸ Se	2,E+06	5,E+10	0								
Total	5,E+10	2,E+11			?						

- systematics performed for $66 \leq A \leq 172$ (n-induced fission)
- RFQ performances and HRS mass resolution?
- Ded to be considered
 - >> impact on scientific program?
 - >> local gas storage before further treatment?
 - >> **DESIR safety report to be produced before June 2008**



LDCA

$$LDCA = \frac{1}{(1/(lae / d / t)) * Dpui} \quad (\text{Bq / m}^3)$$

Lae : Annual limit for the external exposure : 20 mSv

•d : Standard pulmonary flow : 1.2 m³/h

•t : Work time for 1 year : 2000 h

•Dpui : Sv/Bq (given by the regulation)